

The Lincoln County Rural Water System public water system purchases 100% of their water from Lewis and Clark Regional Water System (2288).

## 2022 Table of Detected Regulated Contaminants for Lincoln County Rural Water System (EPA ID 0304)

### Terms and abbreviations used in this table:

- \* Maximum Contaminant Level Goal(MCLG): the level of a contaminant in drinking water below which there is no known or expected risk to health. MCLGs allow for a margin of safety.
- \* Maximum Contaminant Level(MCL): the highest level of a contaminant that is allowed in drinking water. MCLs are set as close to the MCLGs as feasible using the best available treatment technology.
- \* Action Level(AL): the concentration of a contaminant which, when exceeded, triggers treatment or other requirements which a water system must follow. For Lead and Copper, 90% of the samples must be below the AL.
- \* Treatment Technique(TT): A required process intended to reduce the level of a contaminant in drinking water. For turbidity, 95% of samples must be less than 0.3 NTU
- \* Running Annual Average(RAA): Compliance is calculated using the running annual average of samples from designated monitoring locations.

### Units:

- \*MFL: million fibers per liter
- \*pCi/l: picocuries per liter(a measure of radioactivity)
- \*ppt: parts per trillion, or nanograms per liter
- \*mrem/year: millirems per year(a measure of radiation absorbed by the body)
- \*ppm: parts per million, or milligrams per liter(mg/l)
- \*ppq: parts per quadrillion, or picograms per liter
- \*NTU: Nephelometric Turbidity Units
- \*ppb: parts per billion, or micrograms per liter(ug/l)
- \*pspm: positive samples per month

Substance	90% Level	Test Sites > Action Level	Date Tested	Highest Level Allowed (AL)	Ideal Goal	Units	Major Source of Contaminant
Copper	0.1	0	06/17/21	AL=1.3	0	ppm	Corrosion of household plumbing systems; erosion of natural deposits; leaching from wood preservatives.
Lead	2	0	06/11/21	AL=15	0	ppb	Corrosion of household plumbing systems; erosion of natural deposits.

Substance	Highest Level Detected	Range	Date Tested	Highest Level Allowed (MCL)	Ideal Goal (MCLG)	Units	Major Source of Contaminant
Arsenic *	5		10/31/22	10	0	ppb	Erosion of natural deposits; runoff from orchards; runoff from glass and electronics production wastes.
Barium *	0.015		10/31/22	2	2	ppm	Discharge of drilling wastes; discharge from metal refineries; erosion of natural deposits.
Fluoride *	0.80	0.63 - 0.80	04/05/22	4	<4	ppm	Erosion of natural deposits; water additive which promotes strong teeth; discharge from fertilizer and aluminum factories.
Haloacetic Acids (RAA)	17.1		09/06/22	60	0	ppb	By-product of drinking water chlorination. Results are reported as a running annual average of test results.
Nitrate (as Nitrogen) *	0.5		10/04/22	10	10	ppm	Runoff from fertilizer use; leaching from septic tanks, sewage; erosion of natural deposits.
Total trihalomethanes (RAA)	34.4		09/06/22	80	0	ppb	By-product of drinking water chlorination. Results are reported as a running annual average of test results.

Please direct questions regarding this information to Mr. Robin Dykstra with the Lincoln County Rural Water System public water system at (605)767-2966.

\* Lewis and Clark Regional Water System (2288) test result.